



NOTES:

1. SIDEWALKS TO BE SCRIBED IN 4' SQUARES.
2. EXPANSION JOINTS ACROSS THE SIDEWALK NOT LESS THAN 12' APART AND NOT MORE THAN 16' APART.
3. 1/2" PRE FORMED BITUMINOUS EXPANSION JOINT FILLER IN EXPANSION JOINTS TO BE 1/4" WIDE, 1/4" BELOW SURFACE OF SIDEWALK.
4. CONCRETE TO BE 3000 P.S.I., S.H.A. MIX NO. 2
5. WHEN SIDEWALK ABUTS CURB, WALK SHALL BE 1/4" ABOVE CURB.
6. FOR LOCATION OF SIDE WALK SEE DETAILS (R-1 THRU R-17).
7. FOR MODIFICATIONS TO SUIT DRIVEWAYS AND RAMPS SEE DETAIL (R-22 & R-25)
8. 6" x 6" 10 GAUGE WIRE MESH TO BE USED CONTINUOUSLY FOR ALL SIDEWALKS, PLACED 2" CLEAR OF THE BASE.

CECIL
COUNTY
DEPARTMENT
OF
PUBLIC WORKS

STANDARD ROAD & STREET DETAILS

STANDARD 4' SIDEWALK

REVISED

05/07

R-24